

State Water Resources Control Board

September 19, 2018

(Via email and Certified Mail)
CERTIFIED MAIL
NO. 7018 0680 0000 1017 5307

Mr. Clint Turner
Senior Communication Systems Technician
Department of Technology
City and County of San Francisco
200 Paul Avenue, Building B
San Francisco, California 94124
clint.turner@sfgov.gov

**SUBJECT: NOTICE OF VIOLATION; UNDERGROUND STORAGE TANK SYSTEM(S)
LOCATED AT CITY AND COUNTY OF SAN FRANCISCO CENTRAL RADIO
STATION, 1 CHRISTMAS TREE POINT ROAD, SAN FRANCISCO**

Dear Mr. Turner:

As part of an initiative by the State Water Resources Control Board (State Water Board) to ensure compliance at government-owned and/or operated underground storage tank (UST) facilities in California, the State Water Board staff inspected the UST(s) at your facility on September 12, 2018, pursuant to authority under Health and Safety Code (H&SC), chapter 6.7, section 25289.

The State Water Board has identified the following violations pursuant to H&SC, chapter 6.7, and California Code of Regulations (CCR), title 23, chapter 16:

No.	Violation	Tank	Start Date	Stop Date	Regulation
1	Failure to Maintain Plot Plan/Site Map – An approved plot plan/site map indicating the location of the product piping with respect to buildings or other landmarks, was not available in CERS or onsite at the time of the inspection.	All	September 12, 2018	Ongoing	23 CCR 2711(a)(8)
2	Failure to Provide Designated Operator (DO) Training – A current employee training form was not available at the time of inspection. Corrected by the DO at the time of inspection.	All	September 12, 2018	September 12, 2018	23 CCR 2715(f)

No.	Violation	Tank	Start Date	Stop Date	Regulation
3	Failure to Maintain Tank Information – In CERS, under fill components installed, spill bucket and striker plate/bottom protector list “no”; however, they should list “yes.” Additionally, under corrosion protection, isolation lists “no”; however, it should list “yes.”	All	September 12, 2018	Ongoing	23 CCR 2711(a)
4	Failure to Maintain Financial Responsibility – A current copy of the Chief Financial Officer Letter was not available at the time of inspection.	All	September 12, 2018	Ongoing	H&SC 25292.2; 23 CCR 2711(a)(11)

You are directed to correct the ongoing violations and submit compliance documentation to the State Water Board and San Francisco City & County Public Health Department within sixty (60) days from the date of this letter. Have your DO make specific notations in the next monthly DO report indicating the ongoing violations have been corrected. The monthly DO report and any associated photos must be submitted as proof of compliance.

Please send all compliance documentation to the following:

State Water Board

Mr. Douglas McDevitt
UST Enforcement Unit
Office of Enforcement
State Water Resources Control Board
801 K Street, Suite 2300
Sacramento, California 95814
douglas.mcdevitt@waterboards.ca.gov


Local CUPA

Mr. Jin Tang
Senior Environmental Health Inspector
San Francisco City & County
Public Health Department
1390 Market Street, Room 210
San Francisco, California 94102
jin.tang@sfdph.org

Pursuant to Health and Safety Code, chapter 6.7, section 25299, the owner and operator of the tank(s) are liable for a penalty of \$500 to \$5,000 per tank, per day of violation. These penalties will continue to accrue until the violations have been corrected.

If you have any questions, please contact me at (916) 341-5551, or by email at amantha.henkel@waterboards.ca.gov.

Sincerely,



Amantha Henkel
Senior Environmental Scientist
UST Enforcement Unit
Office of Enforcement

cc: See next page.

cc: *(via email only)*

Mr. Jin Tang
Senior Environmental Health Inspector
San Francisco City & County
Public Health Department
jin.tang@sfdph.org

Ms. Paula Stewart
Program Manager
San Francisco City & County
Public Health Department
paula.stewart@sfdph.org

Mr. Mark Kirovsky
Senior Stationary Engineer
City and County of San Francisco
mark.kirovsky@sfgov.org